

**Table 4. Net Present Value of Costs and Benefits of 12 and 13 SEER Air Conditioner and Heat Pump Standards under Various Discount Rates (billion \$2001)**

	<b>SEER 12</b>	<b>S.1766 SEER 13</b>
0 Percent Discount Rate	18.1	16.2
3 Percent Discount Rate	8.2	5.2
7 Percent Discount Rate	2.4	-0.6
10 Percent Discount Rate	0.6	-2.2
15 Percent Discount Rate	-0.7	-2.8

Source: National Energy Modeling System.